



VENT STACK FLASHING

Note:

1. Installation to be completed in accordance with manufacturers specifications.
2. Minimum slope 1/4":12" away from structure is recommended.
3. Plywood substrate to be exterior grade min 5/8" T&G
4. As a supplier of materials only, RPW Associates Inc. Does not assume responsibility for errors in design engineering quantities or dimensions. The architects contractors representatives must verify all dimensions sizes and suitability of details
5. Do not scale drawing.

Project Name	RPW Associates, Inc. PO Box 35 Milton Ontario L9T 2Y3		
Project Address	Project #		
Drawing Title PREFABRICATION VENT PIPE FLASHING DETAIL	DATE: Nov 11/10	DRAWING NUMBER: M211-002	